

# ADDENDUM

RE: City of Mobile Bid #6057 for BAGGAGE PICK UP TABLES

June 9, 2026



Please consider the following to be Addendum to City of Mobile Bid #6057 for BAGGAGE PICK UP TABLES.

The following to be additional information and/or clarification to Bid #6057 for Baggage Pick Up Tables:

1) What is the overall width and length of the Stainless-steel part of the tables, there is an unspecified gap between the tubing frame and the Stainless tabletop?

43.25 inches total width including metal wrapped around edges. 92 inches total length including metal wrapped edges.

Gaps between metal table edge and edge of tubing is 2.75 inches wide.

2) What is the Thickness/Gauge of the Stainless-steel cover material over the plywood?

16 Gauge

3) Is the Stainless Cover to be glued to the Plywood?

Yes. Glued using industry standard epoxy with metal to wood adhesion.

4) Is there a certain Grade of Plywood to be used for the tabletop?

B+, hardwood cabinet grade, non-pressure treated plywood

5) What is the Diameter and Thickness of the Tubing frame and legs?

1.25 inch Schedule 40

6) The Height calls for 36", is that from the floor to the top of the table surface?

Height from floor to top of table is 38 inches

7) What is the Wheel Diameter on the Casters?

1.5 inch diameter caster, connected with threaded metal rod through bottom of leg

Thank you for your consideration in this matter.

Sincerely,

A handwritten signature in blue ink, appearing to read 'John Paine'.

John Paine  
Purchasing Agent  
City of Mobile  
JP/lw